

SPO_1	Ściana podziemia przylegająca do gruntu 1	200,20	200,20	0,368	54,215		
PPO_3	Podłoga zagłębiona 3	618,00	618,00	0,343	114,472		
Mostki							
Symbol przegrody		Symbol mostka			Ψi [W/(mK)]	li [m]	
Zyski i straty dla każdego miesiąca sezonu grzewczego							
	,	styczeń	luty	marzec	kwiecień	maj	czerwiec
θint,H	°C	20	20	20	20	20	20
θe	°C	-1.2	-2.1	0.5	7.5	13	15.2
t_m	[h]	744	672	744	720	744	720
HH	[W/K]	1053.67	1053.67	1053.67	1053.67	1053.67	1053.67
Cm	[J/K]	188706102.00	188706102.00	188706102.00	188706102.00	188706102.00	188706102.00
TH	[h]	49.75	49.75	49.75	49.75	49.75	49.75
aH		4.32	4.32	4.32	4.32	4.32	4.32
QH,ht	[kWh]	16619.34	15648.28	15286.66	9483.04	5487.52	0.00
qint	[W/m²]	5	5	5	5	5	5
Qint	[kWh]	4158.96	3756.48	4158.96	4024.80	4158.96	0.00
Qsol	[kWh]	3202.29	2962.53	6006.66	7637.17	9774.22	0.00
QH,gn	[kWh]	7361.25	6719.01	10165.62	11661.97	13933.18	0.00
γH		0.44	0.43	0.66	1.23	2.54	0.00
ηH,gn		0.98	0.98	0.93	0.72	0.39	0.00
QH,nd,n	[kWh]	9381.69	9030.12	5781.86	1087.83	60.01	0.00
LH	[h]	744.00	672.00	744.00	361.00	0.00	0.00
		lipiec	sierpień	wrzesień	październik	listopad	grudzień
θint,H	°C	20	20	20	20	20	20
θe	°C	17.7	16	12.7	8.5	2.3	0
t_m	[h]	744	744	720	744	720	744
HH	[W/K]	1053.67	1053.67	1053.67	1053.67	1053.67	1053.67
Cm	[J/K]	188706102.00	188706102.00	188706102.00	188706102.00	188706102.00	188706102.00
TH	[h]	49.75	49.75	49.75	49.75	49.75	49.75
aH		4.32	4.32	4.32	4.32	4.32	4.32
QH,ht	[kWh]	0.00	0.00	5538.09	9015.21	13427.98	15678.62
qint	[W/m²]	5	5	5	5	5	5
Qint	[kWh]	0.00	0.00	4024.80	4158.96	4024.80	4158.96